



VIEW W/OUT SUPPORTS

2) 4-1-04 PROOF TEST.
 NOTE: 1) HYDRO @ 240 PSIG. MIN.

HEADS	.166" SA-414-G 2:1 S.E.	ES-30-140-H	REV. 9-14-04
	JOGGLE		DATE: 3-2-90
SHELL	.165" SA-414-G	FOR: HANSON STANDARD	
		HORIZ. HOT WATER TANK	
M.A.W.P. 160 PSIG. @ 180 °F		SURFACE AREA = 37.1 SQ. FT.	
ASME. SECTION IV 2001 ADD 2003		INSIDE: EPOXY LINED	
X-RAY: RT-NO / H.L.W.		OUTSIDE: PRIME	
GALLONS: 140 WT. 334 LBS.		CAD-"B" UNDER "STD"-SERIES	
SERIAL NO.		BY: E.S. SCALE: 1"=12"	
N.B.		ROY E. HANSON JR. MFG.	
		1924 COMPTON AVE. LOS ANGELES, CA 90011	