



2) SHELL - 4-22-04 PROOF TEST.
NOTE: 1) HYDRO @ 240 PSIG.

| | | | |
|--------------------------------|-----------------------|--|---------------|
| HEADS | .245" SA-455 2:1 S.E. | ES-48-712-H | REV. 9-17-04 |
| | (.230" MIN.) JOGGLE | | DATE: 10-3-89 |
| SHELL | .200" SA-455 | FOR: HANSON STANDARD | |
| | | HORIZ. HOT WATER TANK | |
| M.A.W.P. 160 PSIG. @ 180 °F | | SURFACE AREA = 113.0 SQ. FT. | |
| ASME SECTION IV 2001 ADD. 2003 | | INSIDE: EPOXY LINED | |
| X-RAY: RT-NO/H.L.W. | | OUTSIDE: PRIME | |
| GALLONS: 712 WT. 1161 LBS. | | CAD-"B" UNDER "STD"-SERIES | |
| SERIAL NO. | | BY: J.G. SCALE: 3/4"=12" | |
| | | ROY E. HANSON JR. MFG. | |
| | | 1924 COMPTON AVE. LOS ANGELES, CA 90011 | |